

AlarmSense Heat Detectors



Product overview	
Product	A1R Heat Detector
Part No.	55000-190
Product	CS Heat Detector
Part No.	55000-193
Complianco	

oomptionee

Product information

CE



AlarmSense detectors can only be used in a system that is powered and controlled by purpose designed AlarmSense fire control panels and indicating equipment*.

FG

There are two heat detectors in the AlarmSense range designed to suit a wide variety of operating conditions. A static heat detector (CS) which responds only when a fixed temperature has been reached and a rate-of-rise detector (A1R) which has a fixed upper limit, but in addition, measures the rate of increase in temperature.

- Can be used for applications where smoke detectors are unsuitable.
- Ideal for environments that are dirty or smoky under normal conditions
- CS detectors are ideal for use in environments with rapid temperature fluctuations such as boiler rooms
- Reduces false alarms
- Quick and simple installation
- 360° visibility of LEDs

* For further information on suitable fire control panels please contact Apollo Technical Sales: techsales@apollo-fire.com

Technical data

All data is supplied subject to change without notice. Specifications are typical at 24 V, 25°C and 50% RH unless otherwise stated.

Detection principle	Heat sensitive resistance using a single NTC thermistor
Sampling frequency	Once every four seconds
Supply voltage	9 V dc to 33 V dc
Supply wiring	Two wire supply, polarity insensitive
Quiescent current at 15 V	< 50 µA
Alarm current at	
10.5 - 15 V 18 - 24 V	< 1.5 mA 25 ± 2 mA < 1.5 mA < 2 mA
Maximum reset voltage	2 V
Reset time	1 sec
Max supply interruption time	40 ms
Operating temperature	
	-40 °C to +50 °C -40 °C to +80 °C
Humidity (no condensation or icing)	0% to 95% RH
IP Rating	designed to IP44
Standards and approvals	EN 54-5, CPR and FG
Dimensions	100 mm diameter x 42 mm height 100 mm diameter x 50 mm height in base
Weight	80 g detector
Materials	Housing: White flame-retardant polycarbonate Terminals: Nickel plated stainless steel

EMC Directive 2014/30/EU

The AlarmSense Heat Detectors comply with the essential requirements of the EMC Directive 2014/30/EU, provided that they are used as described in this datasheet.

Conformity of the AlarmSense Heat Detectors with the EMC Directive, does not confer compliance with the directive on any apparatus or systems connected to it.

A copy of the Declaration of Conformity is available from Apollo upon request.

Construction Products Regulation 305/2011/EU

The AlarmSense Heat Detectors comply with the essential requirements of the Construction Products Regulation 305/2011/EU.

A copy of the Declaration of Performance is available from Apollo upon request.

 36 Brookside Road, Havant
 Tel: +44 (0)23 9249 2412

 Hampshire, P09 1JR, UK.
 Fax: +44 (0)23 9249 2754

All information in this document is given in good faith but Apollo Fire Detectors Ltd cannot be held responsible for any omissions or errors. The company reserves the right to change the specifications of products at any time and without prior notice.





A HALMA COMPANY © Apollo Fire Detectors Ltd 2019

Email: sales@apollo-fire.com

Web: www.apollo-fire.co.uk





This page has intentionally been left blank

